



Instructions For HCL #5033

32 ounce Personal Emergency Eye Wash Station

1. Wash the Eye Wash Bottle and all the accessory parts: cap, long nozzle, special top, etc. in a detergent solution.
2. Rinse well to remove all traces of detergent.
3. When filling, do not squeeze bottle as airborne bacteria may be introduced when air re-enters.
4. Under clean conditions, fill bottle completely with tap water.
5. Replace top, close cap and return the bottle to the emergency station.
6. If a bottle is used, empty it completely and repeat steps 1-5.
7. Check and refill with new solution as outlined in steps 1-5 once every month.
8. After using an eye wash bottle, the patient should see a physician at once for examination and treatment.



Instructions For HCL #5033

32 ounce Personal Emergency Eye Wash Station

1. Wash the Eye Wash Bottle and all the accessory parts: cap, long nozzle, special top, etc. in a detergent solution.
2. Rinse well to remove all traces of detergent.
3. When filling, do not squeeze bottle as airborne bacteria may be introduced when air re-enters.
4. Under clean conditions, fill bottle completely with tap water.
5. Replace top, close cap and return the bottle to the emergency station.
6. If a bottle is used, empty it completely and repeat steps 1-5.
7. Check and refill with new solution as outlined in steps 1-5 once every month.
8. After using an eye wash bottle, the patient should see a physician at once for examination and treatment.



Sheet#5032
Rev.070903



Sheet#5032
Rev.070903

Call Free 1-800-848-1633 • Fax Free 1-800-447-2923
International Call (740) 477-1686 • International Fax (740) 477-2923

Call Free 1-800-848-1633 • Fax Free 1-800-447-2923
International Call (740) 477-1686 • International Fax (740) 477-2923